


# ADD 63.5 [2.50] IN HEIGHT TO ALLOW FOR REMOVAL OF LID 157.8 [6.21] 9.5 [0.38] 74.9 [2.95]







### NAMEPLATE





Telemetering Equipment for use in Hazardous Locations WARNING: Disconnect the power before servicing. Keep tightly closed during operation. Must be known to be non-hazardous area before servicing. Clean only with damp cloth.

Ex db IIC T6/T5/T4/T3 Gb; -50°C $\leq$  Ta  $\leq$  60°C/75°C/110°C/175°C IP66/67 SWITCH: 3mA @ 8VDC NAMUR Output;







### MODEL NUMBER

# DXP-E2CGSEB

### PRODUCT LINE

## Switchbox DXP and DXS

### **SPECIFICATIONS**

Enclosure Tropicalized aluminum

Bus/Sensor NJ2-V3-N Area Classification Flame proof

Visual Display Standard 90° Green OPEN, Red CLOSED


Shaft  $\frac{1}{4}$  DD 316 stainless steel

Conduit Entries (2)  $\frac{3}{4}$  NPT O-Rings Buna-N

Pilot No pilot device(s)
Spool Valve No spool valve
Valve Cv No valve Cv
Manual Override
Regional Certification
No regional certification

N Switch No N Switch

### **WIRING DIAGRAM**



Current as of September 12, 2023 – Subject to change without notice.

# **Topworx**

3300 Fern Valley Road Louisville, KY 40213 (502)969-8000 PH (502)969-5911 FAX www.topworx.com

Model #:

Serial #: