


- ADD 63.5 [2.50] IN HEIGHT TO ALLOW FOR REMOVAL OF LID 157.8 [6.21] 31.4 [1.24] 4.0 [0.16] -- 74.9 [2.95]







NAMEPLATE





опасных зонах ПРЕДУПРЕЖДЕНИЕ: Перед обслуживанием отключите питание. Во время работы оборудование должно быть плотно закрытым. Перед обслуживанием спедует убедиться, что зона не опасна. Чистите только влажной тряпкой.

 $1 \text{ Ex db IIC T6/T5/T4/T3 Gb X; } -50^{\circ}\text{C} \le Ta \le 60^{\circ}\text{C}/75^{\circ}\text{C}/110^{\circ}\text{C}/175^{\circ}\text{C}}$ IP66/67 SWITCH: SPDT 4A/120VAC; 3A/24VDC Hermetically Sealed;







MODEL NUMBER

DXP-L2CGNMB0000R

PRODUCT LINE

Switchbox DXP and DXS

SPECIFICATIONS

Enclosure Tropicalized aluminum

(2) GOTM Switches SPDT hermetic seal Bus/Sensor

Area Classification Flame proof

Standard 90° Green OPEN, Red CLOSED Visual Display

Shaft NAMUR 316 stainless steel


(2) M20 Conduit Entries O-Rings Buna-N

No pilot device(s) Pilot Spool Valve No spool valve No valve Cv Valve Cv Manual Override No manual override

Regional Certification EAC

N Switch No N Switch

WIRING DIAGRAM



Current as of September 12, 2023 - Subject to change without notice.

TOPWORX

3300 Fern Valley Road Louisville, KY 40213

(502)969-8000 PH (502)969-5911 FAX www.topworx.com

Model #:

Serial #: